

# Factsheet

## Demonstration of gas-powered devices without an exhaust system

As a general rule, all exhaust gases and vapours must be conducted outside by an appropriate exhaust duct. The following provisions shall apply for all devices (exhibits) that are not equipped for the connection of an exhaust duct.

1. Gas-powered devices without an exhaust duct cannot be kept in continuous operation.
2. These devices may only be operated for the purposes of customer demonstrations.
3. The duration of operation must be limited to no more than ten minutes per hour.
4. The devices being presented in operation must be positioned and secured such that they pose no danger to people and no objects in the vicinity could catch fire.
5. Please note that there must be a fire extinguisher at each stand. The fire extinguishers must have an extinguishing capacity of at least 27A for fire class A or 144B for fire class B and should not be heavier than 12 kg.

In addition, Messe Frankfurt's Technical Guidelines must also be observed, particularly:

- 5.6 Machinery, pressure vessels, exhaust systems
- 5.7 Employment of compressed gases, liquefied gases and combustible liquids

In the event of non-compliance with the aforementioned provisions, the Frankfurt Fire Brigade and Messe Frankfurt Venue GmbH reserve the right to undertake further measures.

Messe Frankfurt Venue GmbH  
Technical Project Management Fairs